

SUPPLEMENTAL/ BID BULLETIN

Republic of the Philippines
Calamba Water District
Lakeview Subd, Halang, Calamba City
Tel. Nos: (049) 545-2728; 545-1614; 545-1389
Fax No: (049) 545-9752/502-7108
E-mail add: cwd_bac@yahoo.com

ADDENDUM NO. 1

20 June 2022

AMENDMENTS TO BIDDING DOCUMENTS

Under SECTION VII. Technical Specifications – Submersible Pump System Capacity, Electrical Operation and Letter E of Documents included in the Deliverables thereof should be read as follows:

- I. SECTION VII. Technical Specifications – Submersible Pump System Capacity, Electrical Operation and Letter E of Documents included in the Deliverables

SUBMERSIBLE PUMP SYSTEM CAPACITY:

DRIVEN BY THE FOLLOWING MOTOR	QUANTITY	DISCHARGE CAPACITY m ³ /hr.	TOTAL DYNAMIC HEAD - Meters
75 HP, 460V, 3Ø	4 sets	180	80
50 HP, 460V, 3Ø	2 sets	50	180
40 HP, 460V, 3Ø	1 set	52	160
40 HP, 230V, 3Ø	3 sets	52	160
30 HP, 230V, 3Ø	6 sets	46	100
30 HP, 460V, 3Ø	6 sets	46	100
25 HP, 230V, 3Ø	2 sets	24	180
15 HP, 230V, 3Ø	2 sets	25	100
10 HP, 230V, 1Ø with control capacitor	3 sets	18	90
7.5 HP, 230V, 1Ø with control capacitor	2 sets	16.4	80
5 HP, 230V, 1Ø with control capacitor	1 set	5.6	130
3 HP, 230V, 1Ø with control capacitor	2 sets	3.5	110

ELECTRICAL OPERATION:


MOTOR CAPACITY	QUANTITY	VOLTAGE	PHASE	FREQUENCY
75 HP	4 sets	460V	3Ø	60 Hz
50 HP	2 sets	460V	3Ø	60 Hz
40 HP	1 set	460V	3Ø	60 Hz
40 HP	3 sets	230V	3Ø	60 Hz
30 HP	6 sets	230V	3Ø	60 Hz
30 HP	6 sets	460V	3Ø	60 Hz
25 HP	2 sets	230V	3Ø	60 Hz
15 HP	2 sets	230V	3Ø	60 Hz
10 HP	3 sets	230V	1Ø	60 Hz
7.5 HP	2 sets	230V	1Ø	60 Hz
5 HP	1 set	230V	1Ø	60 Hz
3 HP	2 sets	230V	1Ø	60 Hz

TESTING METHOD AND EQUIPMENT:

The deliverables shall include the following documents:

- e. The supplier has to provide recent quality management certificate **ISO 9001:2015**.

For guidance and information of all concerned.


ENGR. JOSELITO A. GILLERA
BAC Chairman

Received by: _____

Date: _____

Supply and Delivery of Various Pumps and Motors with Complete Accessories (CWD 46-2022)