

SUPPLEMENTAL/ BID BULLETIN

Republic of the Philippines
Calamba Water District
Lakeview Subd, Halang, Calamba City
Tel. Nos: (049) 545-2728; 545-1614; 545-1389
Fax No: (049) 545-9752/502-7108
E-mail add: cwd_bac@yahoo.com

ADDENDUM NO. 1

29 March 2023

AMENDMENTS TO BIDDING DOCUMENTS

Under **SECTION VII. Technical Specifications, WATER METER WITH TAIL PIECE-Paragraph No. 2 and 3 of Meter** thereof should be read as follows:

I. **SECTION VII. Technical Specifications- Paragraph No. 2 and 3 of Meter**

2. **Meter Capacity and Dimensions:**


DIMENSIONS	mm	15	25
Length with tail piece	mm	315	370-420
Width	mm	90 (\pm 5% tolerance)	95-105
Height	mm	100 (\pm 5% tolerance)	100-130
Weight	kg	1.5 (\pm 5% tolerance)	2.7-3.5
Length of tail piece	mm		60 mm
Length with one tail piece @ outlet side with one coupling only	mm	252.5 w/tolerance \pm 0.1mm	

3. Meter body or casing shall be brand new manufactured brass and brass finish with anti-corrosion treatment. Meter bodies shall be smoothly finished free from defects. Bodies which have been repaired are not acceptable. All coating shall be free from defects of any kind. Meter Bodies shall have a common inlet-outlet axis and shall be suitable for horizontal installation. **With CWD Logo will be printed inside the insert at no cost with the procuring entity.**

All external fasteners and seal shall be designed for easily disassembly, after a lengthy in- service use, without the need for special tools or equipment.

Metallurgical test result is subject for verification and retesting by the Procuring Entity and Manufacturer Mill Certificate shall be provided in every delivery.

For guidance and information of all concerned.


MR. EDWIN L. CARTAGO
BAC Chairperson

Received by: _____
Date: _____

Supply and Delivery of Water Meters and Water Meter Test Bench Accessories (Bidding) (CWD 10-2023)