

SUPPLEMENTAL/ BID BULLETIN

Republic of the Philippines
Calamba Water District
Lakeview Subd, Halang, Calamba City
Tel. Nos: (049) 545-2728; 545-1614; 545-1389
Fax No: (049) 545-9752/502-7108
E-mail add: cwd_bac@yahoo.com

ADDENDUM NO. 1

11 May 2022

AMENDMENTS TO BIDDING DOCUMENTS

Under SECTION III. Bid Data Sheet –Clause 20.2, Paragraph 6 and 8 and SECTION VI. Technical Specifications, Meter – Paragraph 3 thereof should be read as follows:

I. SECTION III. Bid Data Sheet –Clause 20.2, Paragraph 6 and 8

20.2	6. Copy of Certificate of Notarial Commission of the Notary Public issued by the Regional Trial Court
	8. Distributorship License from the Manufacturer or Manufacturer's Certification authorizing Supplier to be Distributor of Product being Offered, attached (duly notarized if local product, for imported product, authenticated by the Philippine Consul)

II. SECTION VI. Technical Specifications, Meter – Paragraph 3


Meter

3. Meter body or casing shall be brand new manufactured brass and brass finish with anti-corrosion treatment **or high grade epoxy coated paint**. Meter bodies shall be smoothly finished free from defects. Bodies which have been repaired are not acceptable. All coating shall be free from defects of any kind. Meter bodies shall have a common inlet-outlet axis and shall be suitable for horizontal installation. With CWD Logo and meter number printed **either** inside the insert **or on the body** at no cost with the procuring entity.

All external fasteners and seal shall be designed for easily disassembly, after a lengthy in-service use without the need for special tools or equipment.

Metallurgical test result is subject for verification and retesting by the Procuring Entity and Manufacturer Mill Certificate shall be provided in every delivery.

For guidance and information of all concerned.


ENGR. JOSELITO A. GILLERA
BAC Chairman

Received by: _____

Date: _____

Supply and Delivery of Water Meters and its Accessories (CWD 27-2022)