

## SUPPLEMENTAL/ BID BULLETIN

Republic of the Philippines  
Calamba Water District  
Lakeview Subd, Halang, Calamba City  
Tel. Nos: (049) 545-2728; 545-1614; 545-1389  
Fax No: (049) 545-9752/502-7108  
E-mail add: [cwd\\_bac@yahoo.com](mailto:cwd_bac@yahoo.com)

### ADDENDUM NO. 1

14 November 2022

#### AMENDMENTS TO BIDDING DOCUMENTS

Under SECTION I. Invitation to Bid – Paragraph 2, SECTION III. Bid Data Sheet – Clause 20.2, Requirement No. 8 and 9, SECTION VI. Schedule of Requirements and SECTION VII. Technical Specifications thereof should be read as follows:

I. SECTION I. Invitation to Bid – Paragraph 2

2. The **CALAMBA WATER DISTRICT** now invites bids for the above Procurement Project. Delivery of the Goods is required within **One (1) to Three (3) Months upon receipt of Purchase Order**. Bidders should have completed, within **one (1) year** from the date of submission and receipt of bids, a contract similar to the Project. The description of an eligible bidder is contained in the Bidding Documents, particularly, in Section II (Instructions to Bidders).

II. SECTION III. Bid Data Sheet – Clause 20.2, Requirement No. 8 and 9

20.2	8. ISO Compliant  a. Environmental Management System (14001:2015) – <b>If Available</b>  b. Quality Management System (9001:2015)  9. <b>Bidder/s Notarized Distributorship License from Manufacturers for Local or Imported Products</b>
------	---

III. SECTION VI. Schedule of Requirements

Item Number	Description	Quantity	Total	Delivered, Weeks/Months
	<b>Supply and Delivery of Variable Frequency Drive with the following rating;</b>			<b>Within One (1) to Three (3) Months upon receipt of Purchase Order</b>
1	100HP, 460V, 3Phase	2	Pcs	
2	75HP, 460V, 3Phase	2	Pcs	
3	60HP, 460V, 3Phase	1	Pcs	
4	40HP, 230V, 3Phase	6	Pcs	
5	40HP, VFD, 3Phase, 230V with Phase Converter	3	Pcs	

IV. SECTION VII. Technical Specifications


Variable Frequency Drive with Box Enclosure and Controlled by the following Stuff;

<b>1. Main Circuit Breaker</b>	
1.1 100hp, 460V	250AT
1.2 75hp, 460V	<b>250AT</b>
1.3 60hp, 460V	200AT
1.4 40hp, 230V	<b>250AT</b>
1.5 40hp, 230V with Phase Converter	<b>350 to 400AT</b>
2) Direct on-line stop and start 3) <b>Liquid water level indicator</b> 4) Selector switch for Auto and manual 5) Terminal connector from VFD and submersible cable 6) Light indicator for running and stop 7) Start and running contactor 8) Lightning arrester 9) Terminal block for submersible motor/3-Leads 10) <b>Pressure Transmitter including maximum of 15 meters</b> <b>18/2c Shielded Wire</b> 11) Over/Under Voltage Relay 12) On-Time Delay	

**Relay Outputs for 100hp, 75hp, 60hp and 40hp**

Programmable relay outputs	2
<b>400VAC, 2 A</b>	

For guidance and information of all concerned.

  
**ENGR. JOSELITO A. GILLERA**  
 BAC Chairman

Received by: \_\_\_\_\_  
 Date: \_\_\_\_\_

Supply and Delivery of Variable Frequency Drive (CWD 86-2022)